

Attention Public Water Systems: Community PWS may adapt this form to notify schools of their results. An electronic copy of this form is located at the DEP website at www.state.ma.us/dep/brp/dws/dwsforms.htm under Water Quality Monitoring

LEAD AND COPPER COMPLIANCE SAMPLING PROGRAM SCHOOL RESULTS

City/Town: _____

PWS Name: _____

PWS ID#: _____

Date: _____

Name of School: _____

Sampling Address: _____

Date Sample Collected: _____

Sampling period: _____

Name of Sample Provider: _____ Telephone No: _____ Email address: _____

Dear School Superintendent:

Thank you very much for your participation in the (PWS NAME) Lead and Copper Sampling Program.

The lead and copper levels in your school water samples are as follows:

KITCHEN: LEAD: _____ milligrams per liter (mg/l) COPPER: _____ mg/l
FOUNTAIN: LEAD: _____ milligrams per liter (mg/l) COPPER: _____ mg/l

For schools, the Massachusetts Department of Environmental Protection, Drinking Water Program (MADEP/DWP) Action Level for Lead in school drinking water is 0.015 mg/l. The MADEP/DWP action level is more stringent than the federal Lead Action Level. The standard for Copper is 1.3 mg/l. Even though the lead level in the water at your school is (below/above) the MADEP/DWP Lead Action Level, the City/Town and (PWS NAME) recommend the following tips to keep any potential lead out of the water in your school:

- **Most importantly – Daily before the school is open, please flush all the taps and drinking water fountains at your school until after the water feels cold.** The flushing of the taps ensures the best quality water. The water in the pipe in the street has no lead.
- Never use hot water from the faucet for drinking or cooking.
- Never boil water to remove lead. Boiling water for an extended time may make the lead more concentrated.
- If your results were above the lead or copper action level, follow the guidance in MADEP/DWP document titled “Recommended Remediation Actions to Reduce or Eliminate Lead Exposure from Drinking Water in Schools”. A copy of this document is located at the website address listed below.

If you have any questions regarding lead or copper in drinking water or your sampling results, please feel free to contact: (name) at (telephone number)

For more information on lead or copper in school drinking water visit the following website
<http://www.mass.gov/dep/brp/dws/lead.htm>.

Check box if applicable: ☐ Copy of analytical report attached

cc: DEP regional Office

PWS File